



ITEM	QTY.	PART NUMBER	DESCRIPTION
1	1	1097570	SHELL WELD ASSY.
2	1	1001218	FRONT ASS'Y., RINGLESS
3	1	1008435	INSULATOR SUPPORT ASSY.
4	1	1008302	INSULATOR
5	1	1026583	1/0 CONNECTOR ASS'Y
6	1	1008301	GROUND BUS
7	1	1028309	4 TERM HD BLOCK ASSY.
8	1	1008433	STAKED LEFT LOAD BUS ASSY.
9	1	1008434	STAKED RIGHT LOAD BUS ASSY
10	3	1007327	SINGLE 600kcmil OR DUAL 250kcmil
11	3	1007301	2 POSITION 350kcmil CONNECTOR
12	8	1001273	NUT, 3/8-16 HEX W/BELL
13	8	1001270	WASHER, 3/8 FLAT
14	1	1156422	SCREW 12-24 x 1/2
15	1	1000042	WASHER, 1/4" FLAT SAE
16	1	1104528	SCREW 12-24 x .750
17	3	1000193	SCREW, 12-24 x 3/8
18	3	1123646	SCREW 12-24 X 9/16 HX ST
19	2	1001297	SCREW, 3/8-16 X 1 1/4
20	1	1000166	LABEL, UL METER SOCKET
21	1	1001319	LABEL, RATING U/L
22	1	1001272	LABEL, BY-PASS INSTR.
23	1	1150509	NEUTRAL KIT LABEL
24	1	1000046	LABEL, BOTTOM FEED ONLY
25	1	1000064	LABEL, DANGER
26	1	1000158	PAD WIREMAN, 8.37 x 7.50
27	1	1001317	CARTON (NOT SHOWN)



NOTES:
1. FOR LABELING LOCATION SEE DRAWING #1096668.

REV.	DATE	DESCRIPTION	ECO No.	BY
N1	4/27/15	ADD 1176882 TO RETAIL NOTE	031909	DEF
N2	09-11-19	SEPARATED THIS CONFIGURATION FROM 1797 AND REMOVED CHARTS	043138	MH
O	08/31/21	1000193 WAS 1000183	048736	BLY

FEATURE TABLE		
ITEM	QTY	DESCRIPTION
A	6	STD. MNTG. EMBOSS
B	1	1/4" SOLID K.O.
C	1	1/4", 1/2" CONC. K.O.
D	5	1", 1 1/4", 1 1/2", 2", 2 1/2", 3" CONC. K.O.

Material:	16 GA. STEEL	 <p>MILBANK ENERGY AT WORK KANSAS CITY, MO USA</p>	
Shear/Die No.:	~		
Finish:	MILBANK LIGHT GRAY		
Part Wt.:	31.737 LBS. EA.		
Square Inches:	~	Title:	320A 4T RL SWY HD LVR UG
Tolerances: Unless Specified Otherwise X.X ±.1 X.XX ±.03 X.XXX ±.015 X" ±2"	Third Angle	Catalog No.:	U1797-O-K3L-K2L
Scale:	NTS	Customer:	MILBANK STANDARD
Checked By:		Drawing No.:	1098583
Approved By:		Date:	9/19/2019
Drawn By:	MH	Sheet:	1 of 1